



PO Box 457  
Turramurra NSW 2074

ABN: 69 041 751 671

PH: 0437 251 358  
Email: [philclifton@pclifton.com](mailto:philclifton@pclifton.com)

28 September 2022

Mr John Sabbouh  
Richard Crookes Constructions  
Level 3, 4 Broadcast Way  
Artarmon NSW 2064

**RE: RESULTS OF AIRBORNE ASBESTOS FIBRE MONITORING  
EDUCATION CENTRE AREA AT THE ST JOHN OF GOD RICHMOND HOSPITAL  
177 GROSE VALE ROAD, NORTH RICHMOND NSW**

Dear Sir,

We refer to your request to undertake monitoring for airborne asbestos fibres on Monday 26 September 2022 during the loading out of asbestos contaminated concrete in the area of the former Education Centre building located within the Richard Crookes Constructions site at the St John of God Richmond Hospital, 177 Grose Vale Road, North Richmond NSW.

This monitoring was carried out in accordance the requirements of the Safe Work Australia How to Safely Remove Asbestos Code of Practice, Section 3.11 and the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres' 2<sup>nd</sup> edition [NOHSC 3003:2005].

The results of the monitoring are as follows:

Sample No.	Location	Time On	Time Off	Fibre Count fibres/fields	Airborne Fibre Concentration (fibres/ml)
PCA 7420 - 2022/NR1/33	Education Centre area, at decontamination unit	08:00	15:00	0.0/100	<0.01
PCA 7420 - 2022/NR2/34	Education Centre, north side barricade near site office	08:02	15:02	0.0/100	<0.01

The above results are below the lowest detectable level for the estimation of airborne asbestos fibres using the membrane filter method and below the NOHSC recommended exposure level for airborne asbestos fibres (8 hour TWA) of 0.1 fibres/ml. Green shading indicates results below limit of detection.

This result indicates that there was no measurable human health risk from airborne asbestos fibres in these areas during the monitoring period.



Page 2 of 2  
28 September 2022

The NATA endorsed laboratory report is attached. Samples 28 - 32 on the laboratory report do not relate to work on this day.

If you require any further information, please contact me on 0437 251 358.

Yours faithfully

**P. CLIFTON & ASSOCIATES PTY LTD**

Philip Clifton  
Principal  
BOHS IP402 Certified  
SafeWork NSW Licenced Asbestos Assessor: LAA000119

Attachment: Laboratory Report



## LABORATORY REPORT

## CERTIFICATE OF AIR MONITORING

**Date:** 28 September 2022  
**ESP Job Number:** J47155  
**Customer:** P. Clifton & Associates Pty Ltd  
**Address:** PO Box 457, Turramurra, NSW  
**Attention:** Phil Clifton  
**Sampled From:** As received (Your ref: 7420 - 2022, North Richmond)  
**Sampled By:** As received  
**Date Received:** 28 September 2022  
**Date Analysed:** 28 September 2022  
**Test Method:** Filters examined in accordance with Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres 2<sup>nd</sup> Edition [NOHSC:3003(2005)] using ESP in-house Method No. 1.

ESP Lab No.	Customer Reference	Result (fibres/field)
81151	PO1/28 - St Augustines - Decon (23/9/22)	Nil / 100
81152	PO2/29 - St Augustines - NEG Air	Nil / 100
81153	PO3/30 - Education Centre - Decon	Nil / 100
81154	PO4/31 - Education Centre - North	Nil / 100
81155	PO5/32 - St Augustines - Clearance	Nil / 100
81156	PO1/33 - Education Centre - Decon (26/9/22)	Nil / 100
81157	PO2/34 - Education Centre - North	Nil / 100

The results contained in this report relate only to the sample(s) submitted for testing. ESP Environmental & Safety Professionals accepts no responsibility for the representivity of the sample(s) submitted.

Approved Fibre Counter(s): Ross Cooper  
 Approved Signatory: Eric Salter



Accreditation No. 3110