



PO Box 457
Turramurra NSW 2074

ABN: 69 041 751 671

PH: 0437 251 358
Email: philclifton@pclifton.com

7 October 2022

Mr John Sabbouh
Richard Crookes Constructions
Level 3, 4 Broadcast Way
Artarmon NSW 2064

**RE: RESULTS OF AIRBORNE ASBESTOS FIBRE MONITORING
CTC BUILDING AT THE ST JOHN OF GOD RICHMOND HOSPITAL
177 GROSE VALE ROAD, NORTH RICHMOND NSW**

Dear Sir,

We refer to your request to undertake monitoring for airborne asbestos fibres on Thursday 6 October 2022 during the removal of asbestos backed sheet vinyl floor coverings from within the eastern area in the St Raphaels area in the CTC Building located within the Richard Crookes Constructions site at the St John of God Richmond Hospital, 177 Grose Vale Road, North Richmond NSW.

This monitoring was carried out in accordance the requirements of the Safe Work Australia How to Safely Remove Asbestos Code of Practice, Section 3.11 and the Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres' 2nd edition [NOHSC 3003:2005].

The results of the monitoring are as follows:

Sample No.	Location	Time On	Time Off	Fibre Count fibres/fields	Airborne Fibre Concentration (fibres/ml)
PCA 7420 - 2022/NR1/51	At decontamination unit in centre corridor	07:00	15:15	0.0/100	<0.01
PCA 7420 - 2022/NR2/52	At neg air unit on east side outside building	07:02	15:17	0.0/100	<0.01

The above results are below the lowest detectable level for the estimation of airborne asbestos fibres using the membrane filter method and below the NOHSC recommended exposure level for airborne asbestos fibres (8 hour TWA) of 0.1 fibres/ml. Green shading indicates results below limit of detection.

This result indicates that there was no measurable human health risk from airborne asbestos fibres in these areas during the monitoring period.



Page 2 of 2
7 October 2022

The NATA endorsed laboratory report is attached. Samples 49 - 50 on the laboratory report do not relate to work on this day.

If you require any further information, please contact me on 0437 251 358.

Yours faithfully

P. CLIFTON & ASSOCIATES PTY LTD

Philip Clifton
Principal
BOHS IP402 Certified
SafeWork NSW Licenced Asbestos Assessor: LAA000119

Attachment: Laboratory Report



LABORATORY REPORT

CERTIFICATE OF AIR MONITORING

Date: 7 October 2022
ESP Job Number: J47187
Customer: P. Clifton & Associates Pty Ltd
Address: PO Box 457, Turramurra, NSW
Attention: Phil Clifton
Sampled From: As received (Your ref: 7420-2022)
Sampled By: As received
Date Received: 7 October 2022
Date Analysed: 7 October 2022
Test Method: Filters examined in accordance with Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Fibres 2nd Edition [NOHSC:3003(2005)] using ESP in-house Method No. 1.

ESP Lab No.	Customer Reference	Result (fibres/field)
81280	NR1/49	Nil / 100
81281	NR2/50	Nil / 100
81282	NR1/51	Nil / 100
81283	NR2/52	Nil / 100

The results contained in this report relate only to the sample(s) submitted for testing. ESP Environmental & Safety Professionals accepts no responsibility for the representivity of the sample(s) submitted.

Approved Fibre Counter(s): Ross Cooper
 Approved Signatory: Ross Cooper

